

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010036A
DATE: 10/19/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 525 113 th Street Arlington, TX 76011	Series "CM-2" Aluminum Standard Curb Mount Plastic Dome Skylight Configuration: O Inner Dome: 0.118" Nominal Acrylic Outer Dome: 0.177" Nominal Acrylic Frame: W-1524mm(60") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SKP-C50 1524 x 2438 (60 x 96) Design Pressure (Download): 2400 Pa (50 psf) Negative Design Pressure (Uplift): 2400 Pa (50 psf) Water Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 92882.02-801-44
Expiration Date: August 31, 2013

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122