

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010036B  
DATE: 10/19/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: American  
CODE: 1582-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Skylites</b> <b>525 113<sup>th</sup> Street</b> <b>Arlington, TX 76011</b>	<b>Series "CM-2" Aluminum Standard</b> <b>Curb Mount Plastic Dome Skylight</b>  Configuration: O  Inner Dome: 0.090" Nominal Acrylic  Outer Dome: 0.118" Nominal Acrylic  Frame: W-1524mm(60") H-1829mm(72")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>SKP-C30 1524 x 1829 (60 x 72)</b> Design Pressure (Download): 1440 Pa (30 psf) Negative Design Pressure (Uplift): 1440 Pa (30 psf) Water Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: 92882.02-801-44  
Expiration Date: **August 31, 2013**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122