

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010063A-R2  
DATE: 11/17/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: American  
CODE: 1582-1  
REVISION DATE: 12/10/2009

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Skylites</b> <b>525 113<sup>th</sup> Street</b> <b>Arlington, TX 76011</b>	<b>Series "CMD-100" Aluminum</b> <b>Polycarbonate Double Domed Skylight</b>  Configuration: O  Inner Dome: 1/8" Thick Polycarbonate  Outer Dome: 1/8" Thick Polycarbonate  Frame: W-1359mm(53.5") H-2578mm(101.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-02/E1996-02</b> <b>TAS 201/202/203-94</b>	<b>SKP-HC100 1359 x 2578 (54 x 102)</b> <b>Design Pressure: +100/-100 psf</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 81599.01-801-18/81599.02-801-18/81599.03-801-44  
Expiration Date: September 30, 2012

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122