

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010036.02  
DATE: 10/19/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: American  
CODE: 1582-1  
REVISION DATE: 02/11/2019

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Skylites</b> <b>525 113<sup>th</sup> Street</b> <b>Arlington, TX 76011</b>	<b>Series "CM-2" Aluminum Standard</b> <b>Curb Mount Plastic Dome Skylight</b>  Configuration: O  Inner Dome: 0.090" Nominal Acrylic  Outer Dome: 0.118" Nominal Acrylic  Frame: W-1524mm(60") H-1829mm(72")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>SKP-C30 1524 x 1829 (60 x 72)</b> Design Pressure (Download): 1440 Pa (30 psf) Negative Design Pressure (Uplift): 1440 Pa (30 psf) Water Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: 92882.02-801-44  
Expiration Date: August 31, 2023

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'Shirley' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122