

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010037.01
DATE: 10/19/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 02/11/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 525 113 th Street Arlington, TX 76011	Series "TCM-2" Thermally-Broken Aluminum Curb Mount Plastic Dome Skylight Configuration: O Inner Dome: 0.118" Nominal Acrylic Outer Dome: 0.177" Nominal Acrylic Frame: W-1524mm(60") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SKP-C60 1524 x 2438 (60 x 96) Design Pressure (Download): 2880 Pa (60 psf) Negative Design Pressure (Uplift): 2880 Pa (60 psf) Water Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 92883.02-801-44
Expiration Date: August 31, 2023

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122