

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010063-R2
DATE: 11/17/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 12/10/2009

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 525 113th Street Arlington, TX 76011	Series "SFD-100" Aluminum Polycarbonate Double Domed Skylight Configuration: O Inner Dome: 1/8" Thick Polycarbonate Outer Dome: 1/8" Thick Polycarbonate Frame: W-1327mm(52.25") H-2546mm(100.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/L.S. 2/A440-05 ASTM E1886-02/E1996-02 TAS 201/202/203-94	SKP-HC100 1327 x 2546 (52 x 100) Design Pressure: +100/-100 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: 81599.01-801-18/81599.02-801-18/81599.03-801-44
Expiration Date: September 30, 2012

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122